## ift-Nachweis



Number 23-002593-PR02 (NW-K15-09-en-01)

Owner H.B. Fuller Deutschland GmbH

Niederlassung Henriettenstr. 32 31582 Nienburg/Weser

Germany

Product Wood adhesive

Designation System: Dispersion adhesive, one-component

Shipping name: Rakoll® D3

Details Manufacturer H.B. Fuller Isar-Rakoll S.A.;

Hardener none

Special features 21 days storage at 23/50 after bonding.

Result

Determination of tensile strength of lap joints at elevated temperature (WATT'91) according to EN 14257:2019-09



6.8 N/mm<sup>2</sup>

ift Rosenheim 28.08.2023

Dr. Ing. Odette Moarcas Head of Testing Department Fire Safety Stefan Hehn, Dipl.-Ing. (FH) Operating Testing Officer Material Testing Basis \*)

EN 14257:2019-09

\*) and corresponding national versions (e.g. DIN EN)

Test report: 23-002593-PR02 PB-K15-09-de-01

Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.

When using this document the upto-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: 0D8-34A34





